

INSTALLATION INSTRUCTIONS - 120 BCP 20/SE

The 120-Volt branch circuit protector is a series installed device. *BEFORE INSTALLATION*, verify the amperage and voltage ratings of this device are not exceeded. Circuit breaker *SHOULD MATCH* but *MUST NOT EXCEED* amperage rating of branch circuit suppressor.

Turn off power and connect module as shown in illustration. The suppressor should *NEVER* be installed on a line that is not served by a functional circuit breaker.

The line side is the *UNPROTECTED* side. The *LOAD SIDE* is the *PROTECTED* side going to circuit or equipment protected. The suppressor must be properly oriented with respect to line and load sides or the unit will not function properly. All grounds for systems and equipment must be unified.

When properly installed by a *LICENSED ELECTRICIAN*, the LED indicator will light when the power is restored. Installation questions, please contact Technical Support (323) 312-9449

